

**SOIL/SITE EVALUATION**  
 for ON-SITE WASTEWATER SYSTEM

OWNER: \_\_\_\_\_ APPLICATION DATE \_\_\_\_\_  
 ADDRESS: \_\_\_\_\_ DATE EVALUATED: \_\_\_\_\_  
 PROPOSED FACILITY: House & hanger PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.55  
 LOCATION OF SITE: 1281 Knebworth Lane, Catawba, NC PROPERTY RECORDED: \_\_\_\_\_  
 WATER SUPPLY:  Private  Public  Well  Spring  Other \_\_\_\_\_  
 EVALUATION METHOD:  Auger Boring  Pit  Cut TYPE OF WASTEWATER:  Sewage  Industrial Process  Mixed

P R O F I L E  #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPR CLASS	.1944 RESTR HORIZ	
5	L / 20%	0-6	B L WFGGr	Fr SS SP	N/A	48			S .3
		6-12	YB CL WMS	Fr SS SP					
		12-33	R C WMS	Fr SS SP few sap					
		33-48	R CL WFS	Fr SS SP commn sap					
6	L / 20%	0-10	B SL WFGGr	Fr SS SP	N/A	48			S .3
		10-28	R C WMS	Fr SS SP few sap					
		28-48	R CL WFS	Fr SS SP conn sap					
7	R / 2%	0-8	Y SL WFGGr	Fr SS SP	N/A	29			PS .25
		8-29	R C WMS	Fr SS SP					
8	R / 4%	0-3	Y B L	Fr SS SP	N/A	22			PS .1
		3-22	R C WMS	Fr SS SP					



DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM	OTHER FACTORS (.1946): _____
Available Space (.1945)	200	200	SITE CLASSIFICATION (.1948): <u>PS</u>
System Type(s)	PPBPS	PPBPS	EVALUATED BY: _____
Site LTAR	.3	.3	OTHER(S) PRESENT: <u>Overby</u>

COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_

